

Résultats d'exploitation de la centrale nucléaire de Gösgen 1996 à 2009

Année civile a	Heures à pleine puissance h	Taux d'utilisation %	Production d'énergie en Milliards de kWh	Frais d'exploitation en millions de Francs	Coûts de production cts./kWh
1996	8220.4	93.6	7.928	399.5	5.04
1997	8196.4	93.6	7.908	401.0	5.07
1998	8129.5	92.8	7.840	398.0	5.08
1999	7825.5	89.3	7.534	378.0	5.02
2000	8105.5	92.3	7.804	320.0	4.10
2001	8175.5	93.3	7.870	320.0	4.07
2002	8152.9	93.1	7.853	319.0	4.06
2003	8277.4	94.7	7.989	324.8	4.07
2004	8292.6	94.4	8.016	326.3	4.07
2005	7840.7	89.5	7.583	329.1	4.34
2006	8370.5	95.6	8.099	333.6	4.12
2007	8434.2	96.3	8.159	297.3	3.64
2008	8235.7	93.8	7.964	316.6	3.98
2009	8349.1	95.3	8.072	374.8	4.64